

# POWER QUALITY IMPROVEMENT USING SHUNT HYBRID POWER FILTER

*A Thesis submitted in partial fulfillment of the requirements for the  
degree of Master of Technology*

*In  
Electrical Engineering  
(Control & Automation)*

**By**

**MILI BARAI**

**ROLL NO-210EE3231**



**NATIONAL INSTITUTE OF TECHNOLOGY, ROURKELA**  
**राष्ट्रीय प्रौद्योगिकी संस्थान, राउरकेला**

**DEPARTMENT OF ELECTRICAL ENGINEERING**

**ODISHA, INDIA  
(2010-2012)**

# POWER QUALITY IMPROVEMENT USING SHUNT HYBRID POWER FILTER

*A Thesis submitted in partial fulfillment of the requirements for the  
degree of Master of Technology*

*In  
Electrical Engineering  
(Control & Automation)*

**By**

**MILI BARAI**

**ROLL NO-210EE3231**

**Under the Supervision of**

**Prof. K.B. Mohanty**



**NATIONAL INSTITUTE OF TECHNOLOGY, ROURKELA**  
**राष्ट्रीय प्रौद्योगिकी संस्थान, राउरकेला**

**DEPARTMENT OF ELECTRICAL ENGINEERING**

**ODISHA, INDIA  
(2010-2012)**

**National Institute of Technology, Rourkela**

**Rourkela, Orissa - 769008**



## **CERTIFICATE**

This is to certify that the thesis entitled, **“POWER QUALITY IMPROVEMENT USING SHUNT HYBRID POWER FILTER”** submitted by **Mili Barai, (Roll No-210EE3231)** in partial fulfillment of the award of Master of Technology Degree in Electrical Engineering with specialization in **Control and Automation** during the period **2010-12** at the National Institute of Technology, Rourkela is an authentic work carried out by her under my supervision and guidance.

To the best of my knowledge, the matter embodied in the thesis has not been submitted to any other University/Institute for the award of any degree or diploma.

Date: 14-05-2012  
Place: Rourkela

Prof. K.B. Mohanty  
Dept. of Electrical Engineering  
National Institute of Technology  
Rourkela - 769008

*Dedicated*  
*to*  
*My beloved Parents*  
*and*  
*Brother*

# ACKNOWLEDGEMENT

I would like to articulate my profound gratitude and indebtedness to my thesis guide **Prof. K. B. Mohanty** who has always been a constant motivation and guiding factor throughout the thesis time in and out as well. It has been a great pleasure for me to get an opportunity to work under him and complete the project successfully.

I wish to extend my sincere thanks to **Prof. B. D. Subudhi**, Head of our Department, for approving our project work with great interest.

I would also like to mention Mrs. Madhu Singh, PhD Student, for her cooperation and constantly rendered assistance and my friend, Mr. Bijay BaliarSingh for his help and moral support.

I feel a deep sense of gratitude for my father Sri. Gobinda Barai and mother Smt. Pankajini Barai who formed a part of my vision and taught me the good things that really matter in life. I would like to thank my brother Mr. Lokanath Barai and other family members for their support.

Apart from my efforts, the success of any project depends highly on the encouragement and guidance of many others. I take this opportunity to express my gratitude to the people who have been instrumental in the successful completion of this project. The guidance and support received from all the members who contributed and who are contributing to this project, was vital for the success of the project. I am grateful for their constant support and help.

**MILI BARAI**

**ROLL NO: 210EE3231**

# CONTENTS

<b>ABSTRACT</b>	iv
<b>LIST OF FIGURES</b>	v
<b>LIST OF TABLES</b>	ix
<b>CHAPTER 1</b>	
<b>INTRODUCTION</b>	
1.1 Introduction	2
1.2 Objective	4
1.3 Importance of Power Quality	4
1.4. Cost of Poor Power Quality	5
1.5 Power Quality Parameters (Terminology)	6
1.5.1 Reactive Power and Power Factor ( $\cos \phi$ )	6
1.5.2 Harmonic Distortion	7
1.5.3 Voltage Unbalance	8
1.6 Comparison Between Active and Passive Filter	8
1.7 Comparison Between Series and Shunt Filter	10
1.8 Power Quality Improvement Using LC Passive Filter	10
1.9 Power Quality Improvement Using Active Filter	10
1.10 Power Quality Improvement Using Hybrid Filter	11
1.11 Control Strategies	11
1.12 Conclusion	12

## **CHAPTER 2**

### **POWER QUALITY IMPROVEMENT USING PASSIVE FILTER**

2.1	Introduction	14
2.2	Classification of Passive Filter	15
2.2.1	Shunt Passive Filter	15
2.3	Compensation Principle of Shunt Passive Filter	17
2.4	Design of Shunt Passive Filter	19
2.4.1	Low Pass Filter	19
2.4.2	High Pass Filter	20
2.5	Conclusion	22

## **CHAPTER 3**

### **POWER QUALITY IMPREVEEMENT USING SHUNT HYBRID POWER FILTER**

3.1	Introduction	24
3.2	Modeling of SHPF	26
3.2.1	Model In a-b-c Reference Frame	26
3.2.2	Model Transformation into d-q Reference Frame	28
3.3	Harmonic Current Control	31
3.4	Regulation Of DC Voltage	32
3.5	Conclusion	36

## **CHAPTER 4**

### **CONTROLLER DESIGN**

4.1	Introduction	38
4.2	P-I Controller	38

4.3	Hysteresis Controller	40
4.4	Conclusion	41

## **CHAPTER 5**

### **SIMULATION RESULTS AND DISCUSSION**

5.1	Introduction	43
5.2	Simulation Response of Voltage Source Type Nonlinear Load	43
5.2.1	Simulation Response without Filter	43
5.2.2	Simulation Response with Hybrid Filter	44
5.2.3	Simulation Response using Hysteresis Controller	46
5.2.4	Simulation Response using P-I Controller	47
5.3	Simulation Response of Current Source Type Nonlinear Load	50
5.3.1	Simulation Response without Filter	50
5.3.2	Simulation Response with Hybrid Filter	51
5.3.3	Simulation Response using Hysteresis Controller	52
5.3.4	Simulation Response using P-I Controller	54

## **CHAPTER 6**

### **CONCLUSION AND SCOPE OF FUTURE WORK**

6.1	Conclusion	58
6.2	Scope of Future Work	60

<b>REFERENCES</b>	61
-------------------	----



## **ABSTRACT**

This project report presents design, simulation and development of passive shunt filter and shunt hybrid power filter (SHPF) for mitigation of the power quality problem at ac mains in ac-dc power supply feeding to a nonlinear load. The power filter is consisting of a shunt passive filter connected in series with an active power filter. At first passive filter has been designed to compensate harmonics. The drawback associated with the passive filter like fixed compensation characteristics and resonance problem is tried to solve by SHPF. Simulations for a typical distribution system with a shunt hybrid power filter have been carried out to validate the presented analysis. Harmonic contents of the source current has been calculated and compared for the different cases to demonstrate the influence of harmonic extraction circuit on the harmonic compensation characteristic of the shunt hybrid power filter.

*Key Words: Shunt passive filter, shunt hybrid power filter, harmonic compensation, modeling.*

## LIST OF FIGURES

<b>Figure No</b>	<b>Figure Title</b>	<b>Page No</b>
1	Schematic diagram of shunt passive filter with V-S Type nonlinear load	16
2	Equivalent circuit diagram of passive shunt filter based configuration	18
3	Low pass filter	20
4	High pass filter.	21
5	Schematic diagram of 3-phase SHPF Supplying power to Voltage Source Type and Current Source Type of Nonlinear Load.	25
6	Control loop of the current	32
7	Control loop of the voltage	33
8	Schematic diagram of SHPF with P-I controller	39
9	Block diagram of the Subsystem of P-I Controller	39
10	Schematic diagram of SHPF with Hysteresis Controller	41
11	Wave forms of Supply Voltage (V) without filter.	43
12	Wave forms of Supply Current (A) without filter	43
13	Wave forms of Supply Voltage (V) and Current (A) without filter	44
14	Wave forms of 3-P hase Supply Current (A) Without Filter	44
15	Wave forms of Supply Voltage (V) with hybrid filter	44
16	Wave forms of Supply Current (A) with hybrid filter.	44
17	Wave forms of Supply Voltage and Current with hybrid filter	45
18	Wave forms of 3-P hase Supply Current (A) With hybrid Filter	45

19	Wave forms of 3-P hase Supply Current (A) With hybrid Filter	45
20	Wave forms of Load Current (A) with hybrid filter	45
21	Wave forms of DC Voltage (V) with hybrid filter	45
22	Wave forms of Supply Voltage (V) with hysteresis controller	46
23	Wave forms of Supply Current (A) with hysteresis controller	46
24	Wave forms of Supply Voltage and Current with hysteresis controller	46
25	Wave forms of 3-P hase Supply Current (A) With hysteresis controller	46
26	.26 Wave forms of Filter Current (A) with hysteresis controller	46
27	Wave forms of Load Current (A) with hysteresis controller	47
28	Wave forms of DC Voltage (V) with hysteresis controller	47
29	Wave forms of Supply Voltage (V) with P-I controller	47
30	Wave forms of Supply Current (A) with P-I controller	47
31	Wave forms of Wave forms of Supply Voltage and Current with P-I controller	48
32	Wave forms of 3-P hase Supply Current (A) With P-I controller	48
33	Wave forms of Filter Current (A) with P-I controller	48
34	Wave forms of Load Current (A) P-I controller	48
35	Wave forms of DC Voltage (V) with P-I controller	48
36	THD (%) of the supply Current without filter	49
37	THD (%) of the supply Current with hybrid filter	49
38	THD (%) of the supply Current with hysteresis controller	49
39	THD (%) of the supply Current with P-I controller	49
40	Wave forms of Supply Voltage (V) without filter	50
41	Wave forms of Supply Curent without filter	50

42	Wave forms of Supply Voltage (V) and Current (A) without filter	50
43	Wave forms of 3-Phase supply current without filter	50
44	Wave forms of Load Current (A) without filter	50
45	Wave forms of Supply Voltage (V) without filter	51
46	Wave forms of Supply Current with hybrid filter with hybrid filter.	51
47	Wave forms of Supply Voltage (V) and Current (A) with hybrid filter	51
48	Wave forms of 3-Phase supply current with hybrid filter	51
49	Wave forms of Load Current (A) with hybrid filter	52
50	Wave forms of Filter Current (A) with hybrid filter	52
51	Wave forms of DC Voltage with hybrid filter	52
52	Wave forms of Supply Voltage (V) with hysteresis controller	52
53	Wave forms of Supply Current with hysteresis controller	53
54	Wave forms of Supply Voltage (V) and Current (A) with hysteresis controller	53
55	Wave forms of 3-Phase supply current with hysteresis controller	53
56	Wave forms of Load Current with hysteresis controller	53
57	Wave forms of Filter Current (A) with hysteresis controller	54
58	Wave forms of DC Voltage with hysteresis controller	54
59	Wave forms of Supply Voltage (V) with P-I controller	54
60	Wave forms of Supply Current with P-I controller	54
61	Wave forms of Supply Voltage (V) and Current (A) with P-I controller	55
62	Wave forms of 3-Phase supply current with P-I controller	55
63	Wave forms of Load Current (A) with P-I controller	55
64	Wave forms of Filter Current (A) with P-I controller	55

65	Wave forms of DC Voltage (V) with P-I controller	55
66	THD (%) of the supply Current without filter	56
67	THD (%) of the supply Current with hybrid filter	56
68	THD (%) of the supply Current with hysteresis controller	56
69	THD (%) of the supply Current with P-I controller	56

## LIST OF TABLES

<b>Table No</b>	<b>Table Title</b>	<b>Page No</b>
1	Passive Filter Components	22
2	Voltage Source Type Of Nonlinear Load	59
3	Current Source Type Of Nonlinear Load	59
4	Specification parameters	60

# Chapter 1

## **INTRODUCTION**

*Objective*

*Importance of Power Quality*

*Cost of Poor Power Quality*

*Power Quality Parameters (Terminology)*

*Comparison between Active and Passive Filter*

*Comparison between Series and Shunt Filter*

*Power Quality Improvement Using LC Passive, active and hybrid Filter*

*Control Strategies*

*Conclusion*

## 1.1 INTRODUCTION

Now a day's power electronic based equipment are used in industrial and domestic purpose. These equipments have significant impacts on the quality of supplied voltage and have increased the harmonic current pollution of distribution systems. They have many negative effects on power system equipment and customer, such as additional losses in overhead and underground cables, transformers and rotating electric machines, problem in the operation of the protection systems, over voltage and shunt capacitor, error of measuring instruments, and malfunction of low efficiency of customer sensitive loads.

Passive filter have been used traditionally for mitigating the distortion due to harmonic current in industrial power systems. But they have many drawbacks such as resonance problem, dependency of their performance on the system impedance, absorption of harmonic current of nonlinear load, which could lead to further harmonic propagation through the power system [2].

To overcome of such problem active power filters is introduced. It has no such drawbacks like passive filter. They inject harmonic voltage or current with appropriate magnitudes and phase angle into the system and cancel harmonics of nonlinear loads. But it has also some drawbacks like high initial cost and high power losses due to which it limits there wide application, especially with high power rating system. [3].

To minimize these limitations, hybrid power filter have been introduced and implemented in practical system applications [4] - [8]. Shunt hybrid filter is consists of an active filter which is connected in series with the passive filter and with a three phase PWM inverter. This filter effectively mitigates the problem of a passive and active filter. It provides cost effective harmonic compensation, particularly for high power nonlinear load [5]. Different control



techniques are present for extracting harmonic components of the source current. Some of them are synchronous reference frame (SRF) transformation, instantaneous power (p-q) theory, etc. where high pass filters (HPFs) are used or extracting harmonic components of the source current from the fundamental components [6].

In This thesis, a shunt hybrid power filter (SHPF) is modeled in the stationary “a-b-c” reference frame and then, the model is transformed into the rotating “d-q” reference frame to reduce the control complexity. Two different decoupled current control techniques using proportional–integral (PI)-type controller and hysteresis controller, are implemented to force the current of the filter to track their reference value. On the other hand the dc-voltage of the filter is regulated using P-I controller. The harmonic current of the non-linear load is controls by feeding it to the passive filter, hence no harmonic currents are drawn from the ac mains. LC passive filter is connected with an active filter; the required rating of the active filter is much smaller than that of a stand-alone shunt active filter. Here switching ripple filter is not required because its LC circuit accomplishes the filtering of the switching ripple.

The model is first simulated with the P-I controller and then with the hysteresis controller. Simulation results of both the schemes are observed and it is confirmed the effectiveness of the SHPF in damping and mitigation of harmonics.

## **1.2 OBJECTIVE**

- Design of passive filter for the ac - dc supply system feeding nonlinear load.
- Design of shunt hybrid power filter for ac- dc supply system feeding nonlinear load.
- Simulate both schemes in MATLAB/SIMULINK environment.
- Carry out the comparative study of both schemes on the basis of simulation response.

The diode rectifier interface to the electric utility exhibits nonlinear characteristics, which deteriorate the power quality at the ac mains. The present work aims to eliminating the problem of harmonic in the ac main.

In this research work, various alternatives such as passive filter, active filter, hybrid filter, six pulses PWM converter are implemented.

## **1.3 IMPORTANCE OF POWER QUALITY**

- Power quality is defined by the parameters that express reactive power, harmonic pollution, and load unbalance.
- The best ideal electrical supply would be a sinusoidal voltage waveform with constant magnitude and frequency. But in reality due to the non-zero impedance of the supply system, the large variety of loads may be encountered and of other phenomena such as transients and outages, the reality is often different.
- If the power quality of the network is good, then any load connected to it will run satisfactorily and efficiently. Installation during cost and carbon footprint will be minimal.

- If the power quality of the network is bad, then loads connected to it will fail or will have a reduced lifetime, and the efficiency of the electrical installation will reduce. Installation running cost and carbon footprint will be high and operation may not be possible at all.

#### **1.4 COST OF POOR POWER QUALITY**

Poor Power Quality can be described as any event related to the electrical network that ultimately results in a financial loss. Possible consequences of Poor Power Quality include the followings:

- Unexpected power supply failures (breakers tripping, fuses blowing).
- Equipment failure or malfunctioning.
- Equipment overheating (transformers, motors,) leading to their lifetime reduction.
- Damage to sensitive equipment (PCs, production line control systems,).
- Electronic communication interferences.
- Increase of system losses.
- Need to oversize installations to cope with additional electrical stress with consequential increase of installation and running costs and associated higher carbon footprint.
- Penalties imposed by utilities because the site pollutes the supply network too much.
- Connection refusal of new sites because the site would pollute the supply network too much.
- Impression of unsteadiness of visual sensation induced by a light stimulus whose luminance or spectral distribution fluctuates with time (flicker).
- Health issues with and reduced efficiency of personnel.

The following main contributors to low voltage and poor power quality can be defined:

- Reactive power, which unnecessarily loads up the supply system.
- Harmonic pollution, which causes extra stress on the networks and makes installations run less efficiently.
- Load imbalance, especially in office building applications, as the unbalanced loads may result in excessive voltage imbalance causing stress on other loads connected to the same network, and leading to an increase of neutral current and neutral to earth voltage build-up.
- Fast voltage variations leading to flicker.

If due to poor power quality the production is stopped, major costs are incurred.

## **1.5 POWER QUALITY PARAMETERS (TERMINOLOGY)**

### **1.5.1 REACTIVE POWER AND POWER FACTOR ( $\cos \phi$ ):**

In AC supply, the current is usually phase-shifted from the supply voltage. This leads to different power definition.

- The active power  $P$ [KW], it is responsible for the useful work, which is associated with the portion of the current which is in phase with the voltage.
- The reactive power  $Q$ [KVAR], it sustains the electromagnetic field used to make a motor operate, is an energy exchange (per unit of time) between reactive components of the

electrical system (capacitors and reactors) and source. It is associated with the portion of the current which is phase shifted by  $90^\circ$  with the voltage.

- The apparent power  $S[\text{KVA}]$ , which is a geometrical combination of the active and the reactive powers, can be seen as the total power drawn from the network.

The ratio between the active power and the apparent power is referred to as the power factor ( $\cos \phi$ ) and is a measure of efficient utilization of the electrical energy. Unity power factor ( $\cos \phi$  that equals to 1) refers to the most efficient transfer of useful energy. A  $\cos \phi$ , which is equals to 0 refers to the most inefficient way of transferring energy.

#### 1.5.2 HARMONIC DISTORTION:

The harmonic pollution is generally characterized by the total Harmonic Distortion or THD which is by definition equal to the ratio of the RMS harmonic content to the fundamental:

$$\text{THDV} = \frac{\sqrt{V_{RMS}^2 - V_1^2}}{V_1} = \frac{\sqrt{\sum_{k=2} V_K^2}}{V_1}, \text{ where } V_K \text{ is the } k^{\text{th}} \text{ harmonic component of the signal } V.$$

This quantity, expressed in %, is very useful when the fundamental value component is implicitly given or known. Consequently, the THD is particularly relevant information for the voltage (as the rated voltage is known). In order to be able to gauge THD of the current, it is imperative that a fundamental frequency current reference be defined.

### 1.5.3 VOLTAGE UNBALANCE

Fortes cue has shown in the symmetrical components theory that any three phase system can be expressed as the sum of three symmetrical sets of balanced phasors i.e. the first set having the same phase sequence as the initial system (positive phase sequence), the second set having the inverse phase sequence (negative phase sequence) and the third one consisting of three phasors in phase (zero phase sequence or homopolar components). A normal three phase supply has the three phases of same magnitude but with a phase shifted by  $120^\circ$ . Any deviation (magnitude or phase) of one of the three signals will result in a negative phase sequence component and/or a zero phase sequence component. The definition of voltage unbalance is usually expressed as the ratio between the negative phase sequence component and the positive phase sequence component. This parameter is expressed in %. (Strictly speaking, the homopolar part should also be considered in the definition. However, as it is the negative phase sequence that is the most relevant for causing damage to direct online motors by creating a reverse torque, historically the unbalance definition is often limited to the one expressed in this paragraph).

### 1.6 COMPARISION BETWEEN ACTIVE AND PASSIVE FILTER

#### ACTIVE FILTER:

- They use the active devices and resistor and capacitor. No inductor is used.
- As no inductor is used circuit becomes compact and less in weight even at low frequencies.
- It requires dual power supply.
- Input impedance is high.
- As the output impedance is low, it can drive the low impedance load.

- Load is isolated from the frequency determined by the network. So, variation in load does not affect the characteristic of the filter.
- It is possible to increase the gain.
- Parameters like gain, pass band, cut off frequency can be adjusted.
- High frequency response is limited by gain  $\times$  band width product and slew rate.
- Variation in power supply voltage affects the output voltage. Feedback through common supply rail may cause oscillations.

#### PASSIVE FILTER:

These filters make use of the passive components like inductor, capacitor, resistor etc.

- Circuit becomes bulky and costly especially for low frequency because size of the inductor increases at lower frequency.
- It does not need power supply.
- Input impedance is less which loads the source.
- Output impedance is more. So, it cannot drive the low impedance load.
- Load is not isolated from the frequency determining network, So, variation in load may affects the characteristic of filter.
- It is not possible to increase the gain.
- It is not possible to adjust the parameters.
- No restriction at high frequency.
- No power supply is used. So output is not affected.
- No such problem arises.

## **1.7 COMPARISION BETWEEN SERIES AND SHUNT FILTER**

### **SERIES FILTER:**

- Series filter is connected in series with the circuit.
- It offers a high impedance path to harmonic currents at its tuned frequency.
- Series filter must carry full load currents.
- It is high in cost as compare to shunt filter.

### **SHUNT FILTER:**

- Shunt filter is connected in parallel with the circuit.
- It offers a low impedance path to harmonic currents at its tuned frequency.
- Shunt filters carry only a fraction of the load current.
- It is low in cost as compare to series filter.

## **1.8 POWER QUALITY IMPROVEMENT USING LC PASSIVE FILTER**

During last decade, passive LC filters have been used to eliminate harmonic currents and to improve the power factor of ac mains. However, these passive filters have many drawbacks such as tuning problems and series and parallel resonances [2]. To avoid this resonance between an existing passive filter and the supply impedance, typical shunt or series active filter topologies have been proposed in the literature [3].

## **1.9 POWER QUALITY IMPROVEMENT USING ACTIVE FILTER**

Active filter suffer from high kilovolt-ampere rating. The boost-converter forming the shunt active filter requires high dc-link voltage in order to effectively compensate higher order



harmonics. On the other hand, a series active filter needs a transformer that is capable to withstand full load current in order to compensate for voltage distortion [4], [6].

### **1.10 POWER QUALITY IMPROVEMENT USING HYBRID FILTER**

Hybrid filters provide cost-effective harmonic compensation particularly for high-power nonlinear load [7]. A parallel hybrid power filter system consists of a small rating active filter in series with a passive filter. The active filter is controlled to act as a harmonic compensator for the load by confining all the harmonic currents into the passive filter. This eliminates the possibility of series and parallel resonance [8], [9].

### **1.11 CONTROL STRATEGIES**

A number of control concepts and strategies of active power filters have been reported in the literature [10]-[12]. The most popular are time domain methods such as the notch filter, the instantaneous reactive power theory, and the synchronous reference frame theory. In [11], a nonlinear control technique is proposed to enhance the dynamic performance of a shunt active power filter which is modeled in the synchronous orthogonal d-q frame. In [12], the authors reported an adaptive nonlinear control law to a three-phase three-level neutral-point-clamped boost rectifier operating under severe conditions. The control techniques consist in applying an adaptive nonlinear control to the exact nonlinear model of the rectifier obtained in the (d, q, 0) reference frame. In [12], linear and nonlinear controllers are employed for a three-level rectifier for harmonic and dc-voltage regulation.

## **1.12 CONCLUSION**

This chapter focuses regarding the objective of the project and basic ideas of filter. We can know the importance of power quality, and its parameter. The types of filters and difference between them are elaborated in this chapter. It indicated the various research works which has been done in power quality improvement by using different types of filters in different areas.

# Chapter 2

## **POWER QUALITY IMPROVEMENT USING PASSIVE FILTER**

*Introduction*

*Classification of Passive Filter*

*Design and compensation principle of shunt passive filter*

*Conclusion*

## 2.1 INTRODUCTION

The passive filters are used to mitigate power quality problems in six-pulse ac-dc converter. Apart from mitigating the current harmonics, the passive filters also provide reactive power compensation, thereby, further improving the system performance. For current source type of loads, generally, passive shunt filters are recommended [114]. These filters, apart from mitigating the current harmonics, also provide limited reactive power compensation and dc bus voltage regulation. However, the performance of these filters depends heavily on the source impedance present in the system because these filters act as sinks for the harmonic currents. For voltage source type harmonic producing loads, the use of series passive filter is recommended [114]. These filters block the flow of harmonic currents into ac mains, by providing high impedance path at certain harmonic frequencies for which the filter is tuned. Moreover, the harmonic compensation is practically independent of the source impedance. But, passive series filters suffer due to the reduction in dc link voltage drop across the filter components at both fundamental and harmonic frequencies.

This chapter presents a detailed investigation into the use of different configurations of passive shunt filters. The advantages and disadvantages are discussed. It is observed that these configurations fail to meet the IEEE standard 519 guidelines under varying load conditions. The configuration of passive hybrid filter is designed for power quality improvement. The main advantages of this configuration is that it can achieve the improved power quality even under varying load conditions, its rating is less and it can maintain the dc link voltage regulation within certain limits.

## 2.2 CLASSIFICATION OF PASSIVE FILTERS

Depending on the connection of different passive components, the passive filters are classified as below:

- Passive series filter
- Passive shunt filter

My scope of work is on shunt passive and hybrid filter.

### 2.2.1 SHUNT PASSIVE FILTER:

Fig.1. shows the schematic diagram of a passive shunt filter connected at input ac mains of six pulse ac-dc converters fed to a nonlinear load. This is the commonly used configuration of passive filter. It consists of a low pass shunt filters tuned at 5<sup>th</sup> and 7<sup>th</sup> harmonic frequencies and high pass filter tuned for 11<sup>th</sup> harmonic frequencies. These passive filters scheme helps in sinking the more dominant 5<sup>th</sup>, 7<sup>th</sup> and other order harmonic and thus prevents them flowing into ac mains.




Fig.1 Schematic diagram of shunt passive filter with V-S Type nonlinear load

### 2.3 COMPENSATION PRINCIPLE OF SHUNT PASSIVE FILTER

A passive shunt filter consists of several LCR branches each tuned at particular frequency. Fig.2 shows the equivalent circuit diagram of a passive shunt filter. The compensation principle of LC passive shunt filter is as follows:

$$\frac{I_s}{V_1} = \frac{Z_{sh}}{Z_1 Z_s + Z_1 Z_{sh} + Z_s Z_{sh}} \quad (1)$$

Where  $Z_{sh}$  is the impedance of the parallel LC filter. From (1) it can be seen that the performance of parallel LC filter depends on the source impedance and is determined only by the ratio of the source impedance and the filter impedance.

If  $Z_1 = 0$ , then  $I_s = I_1$ , which means that the passive filter is not effective. But if  $Z_s = 0$ , then  $\frac{I_s}{V_1} = \frac{1}{Z_1}$ , which means that the filter does not provide harmonic compensation.

It is seen that the filter interaction with the source impedance results in a parallel resonance. For inductive source impedance ( $Z_s$ ), this occurs at a frequency below the frequency at which the filter is tuned. It is as follows:

$$f_{sys} = \frac{1}{2\pi(L_s + L)C} \quad (2)$$

If the filter is tuned exactly at a concern frequency then an upward shift in the tuned frequency results in a sharp increase in impedance as seen by the harmonic. There are some common mechanisms which may cause filter detuning. They are as follows:

- Capacitor fuse-blowing, which lowers the total capacitance, thereby raising the frequency at the filter has been tuned.
- Temperature variation
- System parameter variation
- Manufacturing tolerances in both inductor as well as capacitor.

So the filter banks are tuned to around 6% below the desired frequency as per IEEE standard 1531 [23].




Fig.2 Equivalent circuit diagram of passive shunt filter based configuration



## 2.4 DESIGN OF SHUNT PASSIVE FILTER

The passive shunt filter consists of first order series tuned low pass filters tuned for 5<sup>th</sup> and 7<sup>th</sup> harmonics and a second order damped high pass filter tuned for 11<sup>th</sup> harmonics.

### 2.4.1 LOW PASS FILTER:

For the series tuned low pass filter the impedance is:

$$Z_{sh(h)} = \left[ R + j(hX_L - \frac{X_C}{h}) \right] \quad (3)$$

$$X_C = \frac{V_{ph}^2}{Q_{sh} h} \quad (4)$$

$$X_L = \frac{X_C}{h_n^2} \quad (5)$$

Where  $Q_{sh}$  = reactive power provided by the passive filter in VAR per phase,  $X_L$  = reactance of inductor,  $X_C$  = reactance of capacitor,  $h$  = harmonic order of the passive filter,  $V_{ph}$ =Phase voltage

Initially the reactive power requirement is assumed to be 25% of the rating of the load [112]. It may be equally divided into different filter branches. The value of series tuned element can be calculated from (4) and (5). The quality factor of the low pass filter is:

$$QF = \frac{X_L}{R} \quad (6)$$

Here the quality factor is assumed to 30 to calculate the value of the resistive element. The resonant frequency is given by

$$f_0 = \frac{1}{2\pi\sqrt{LC}} \quad (7)$$

Where R = filter resistance

L = filter inductance

C = filter capacitance




Fig.3. Low pass filter.

#### 2.4.2 HIGH PASS FILTER:

For second order damped filter, the impedance at any harmonics h becomes:

$$Z_{sh} = \left[ \frac{R(hX_L)^2}{R^2 + (hX_L)^2} + j\left(\frac{R^2 hX_L}{R^2 + (hX_L)^2} - \frac{X_C}{h}\right) \right] \quad (8)$$

$$X_C = \left( \frac{h_n^2}{h_n^2 - 1} \right) \frac{V^2}{Q_{sh}} \quad (9)$$

Resonant frequency for  $h^{\text{th}}$  harmonic is

$$f_0 = \frac{1}{2\pi hCR} \quad (10)$$

Quality factor can be expressed as

$$QF = \frac{L}{R^2 C} \quad (11)$$




Fig.4. High pass filter.

The design of passive shunt filter is carried out as per the reactive power requirements. The filter is designed to compensate the reactive power of the system. Hence the passive filter helps in maintaining the regulation of dc link voltage within limits and power factor improvement as improving the THD of supply current. It also sinks the harmonic currents of the frequencies at which the passive filter has been tuned.

Depending on the harmonic spectrum of the supply current passive filter is designed for low pass filters which is tuned for 5<sup>th</sup> and 7<sup>th</sup> harmonic frequency and high pass filter which is tuned for 11<sup>th</sup> harmonic frequency shown in Fig.1. In low pass filter Fig.3 R, L, and C are connected in series. The high pass filter Fig.4 consists of a capacitor which is connected in series with the parallel combination of the resistor and inductor to the converter.

In this research work passive LC filter is designed for the 5<sup>th</sup> and 7<sup>th</sup> order harmonic frequency, and the filter component values are:

**Table 1**

**Passive Filter Components**

5 <sup>th</sup>	$C_5=11.24\text{e-}3$	$L_5=0.9\text{e-}3$
7 <sup>th</sup>	$C_7=15.7\text{e-}3$	$L_7=0.64\text{e-}3$

## 2.5 CONCLUSION

This chapter described about the shunt passive filter. It elaborated the design and compensation principle of passive filter for low pass and high pass filter. In this project work the low pass filter is tuned for 5<sup>th</sup> and 7<sup>th</sup> order harmonic frequencies. The values of the filter component are given in table 1.

# Chapter 3

## **POWER QUALITY IMPROVEMENT USING SHUNT HYBRID POWER FILTER**

*Introduction*

*Modeling of SHPF*

*Harmonic Current Control*

*Regulation of DC Voltage*

*Conclusion*

### **3.1 INTRODUCTION**

The schematic diagram of the shunt hybrid power filter (SHPF) is presented in Fig. 1. The scheme contains the three phase supply voltage, three phase diode rectifier and the filtering system consists of a small-rating active power filter connected in series with the LC passive filter. This configuration of hybrid filter ensures the compensation of the source current harmonics by enhancing the compensation characteristics of the passive filter besides eliminating the risk of resonance. It provides effective compensation of current harmonics and limited supply voltage distortion. The hybrid filter is controlled such that the harmonic currents of the nonlinear loads flow through the passive filter and that only the fundamental frequency component of the load current is to be supplied by the ac mains.




Fig.5 Schematic diagram of 3-phase SHPF Supplying power to Voltage Source Type and Current Source Type Nonlinear Load.

## 3.2 MODELLING OF THE SHPF

### 3.2.1 MODEL IN a-b-c REFERENCE FRAME:

Kirchhoff's law of voltage and currents applied to this system provide three differential equations in the stationary "a-b-c" frame (for  $k = 1, 2, 3$ )

$$v_{sk} = L_{PF} \frac{di_{ck}}{dt} + R_{PF} i_{ck} + \frac{1}{C_{PF}} \int i_{ck} dt + v_{kM} + v_{MN} \quad (12)$$

Differentiating (12) we get

$$\frac{dv_{sk}}{dt} = L_{PF} \frac{d^2 i_{ck}}{dt^2} + R_{PF} \frac{di_{ck}}{dt} + \frac{1}{C_{PF}} i_{ck} + \frac{dv_{kM}}{dt} + \frac{dv_{MN}}{dt} \quad (13)$$

Assume that the zero sequence current is absent in a three phase system and the source voltages are balanced, so we obtain:

$$v_{MN} = - \frac{1}{3} \sum_{k=1}^3 v_{kM} \quad (14)$$

We can define the switching function  $C_k$  of the converter  $k^{\text{th}}$  leg as being the binary state of the two switches  $S_k$  and  $S'_k$ . Hence, the switching  $C_k$  (for  $k = 1, 2, 3$ ) is defined as

$C_k = 1$ , if  $S_k$  is On and  $S'_k$  is Off,

$C_k = 0$ , if  $S_k$  is Off and  $S'_k$  is On. (15)

Thus, with  $V_{kM} = C_k V_{dc}$ , and from (15), the following relation is obtained:



$$\frac{d^2 i_{ck}}{dt^2} = -\frac{R_{PF}}{L_{PF}} \frac{di_{ck}}{dt} - \frac{1}{C_{PF} L_{PF}} i_{ck} - \frac{1}{L_{PF}} \left( c_k - \frac{1}{3} \sum_{m=1}^3 c_m \right) \frac{dv_{dc}}{dt} + \frac{1}{L_{PF}} \frac{dv_{sk}}{dt} \quad (16)$$

Let the switching state function be defined as

$$q_{nk} = \left( c_k - \frac{1}{3} \sum_{m=1}^3 c_m \right) n \quad (17)$$

The value of  $q_{nk}$  depends on the switching state  $n$  and on the phase  $k$ . This shows the interaction between the three phases. Conversion from  $[C_k]$  to  $[q_{nk}]$  is as follows

$$q_{n1} = \frac{2}{3} c_1 - \frac{1}{3} c_2 - \frac{1}{3} c_3 \quad (18)$$

$$q_{n2} = -\frac{1}{3} c_1 + \frac{2}{3} c_2 - \frac{1}{3} c_3 \quad (19)$$

$$q_{n3} = -\frac{1}{3} c_1 - \frac{1}{3} c_2 + \frac{2}{3} c_3 \quad (20)$$

Hence we got the relation as

$$\begin{bmatrix} q_{n1} \\ q_{n2} \\ q_{n3} \end{bmatrix} = \frac{1}{3} \begin{bmatrix} 2 & -1 & -1 \\ -1 & 2 & -1 \\ -1 & -1 & 2 \end{bmatrix} \begin{bmatrix} c_1 \\ c_2 \\ c_3 \end{bmatrix} \quad (21)$$

The matrix in (21) is of rank 2  $q_{nk}$  has no zero sequence components. By the analysis of the dc component of the system it gives

$$dv_{dc} = \frac{1}{c_{dc}} i_{dc} = \frac{1}{c_{dc}} \sum_{k=1}^3 q_{nk} i_{ck} \quad (22)$$

With the absence of zero sequence components in  $i_k$  and  $q_{nk}$  one can get

$$\frac{dv_{dc}}{dt} - \frac{1}{c_{dc}} (2q_{n1} + q_{n2}) i_{c1} + \frac{1}{c_{dc}} (q_{n1} + 2q_{n2}) i_{c2} \quad (23)$$

Hence the complete model of the active filter in “a-b-c” reference frame is obtained as follows

The application of (16) for phase 12 and 13 with (23)

$$L_{PF} \frac{d^2 i_{c1}}{dt^2} = -R_{PF} \frac{di_{c1}}{dt} - \frac{1}{C_{PF}} i_{c1} - q_{n1} \frac{dv_{dc}}{dt} + \frac{dv_{s1}}{dt}$$

$$L_{PF} \frac{d^2 i_{c2}}{dt^2} = -R_{PF} \frac{di_{c2}}{dt} - \frac{1}{C_{PF}} i_{c2} - q_{n2} \frac{dv_{dc}}{dt} + \frac{dv_{s2}}{dt}$$

$$C_{dc} \frac{dv_{dc}}{dt} = (2q_{n1} + q_{n2}) i_{c1} + (q_{n1} + 2q_{n2}) i_{c2} \quad (24)$$

The above model is time varying and nonlinear in nature.

### 3.2.2 MODEL TRANSFORMATION INTO “d-q” REFERENCE FRAME:

Since the steady state fundamental components are sinusoidal, the system is transformed into the

synchronous orthogonal frame rotating at constant supply frequency. The conversion matrix is

$$C_{dq}^{123} = \sqrt{\frac{2}{3}} \begin{bmatrix} \cos \theta & \cos(\theta - 2\pi/3) & \cos(\theta - 4\pi/3) \\ -\sin \theta & -\sin(\theta - 2\pi/3) & -\sin(\theta - 4\pi/3) \end{bmatrix} \quad (25)$$

where  $\theta = \omega t$ , and the following equalities hold:

$$C_{123}^{dq} = (C_{dq}^{123})^{-1} = (C_{dq}^{123})^T$$

$$\text{Now(23) is } \frac{dv_{dc}}{dt} = \frac{1}{C_{dc}} (q_{n123})^T (i_{c123}) \quad (26)$$

Applying coordination transformation

$$\frac{dv_{dc}}{dt} = \frac{1}{C_{dc}} (C_{123}^{dq} [q_{ndq}]^T (C_{123}^{dq} [i_{dq}]) = \frac{1}{C_{dc}} [q_{ndq}]^T [i_{dq}] \quad (27)$$

On the other hand, the two first equations in (24) are written as

$$\frac{d^2}{dt^2} [i_{c12}] = -\frac{R_{PF}}{L_{PF}} \frac{d}{dt} [i_{c12}] - \frac{1}{C_{PF} L_{PF}} [i_{c12}] - \frac{1}{L_{PF}} [q_{n12}] \frac{dv_{dc}}{dt} + \frac{1}{L_{PF}} \frac{d}{dt} [v_{s12}] \quad (28)$$

The reduced matrix can be used

$$C_{dq}^{12} = \sqrt{2} \begin{bmatrix} \cos(\theta - \pi/6) & \sin \theta \\ -\sin(\theta - \pi/6) & \cos \theta \end{bmatrix} \quad (29)$$

It has the following inverse

$$C_{12}^{dq} = \sqrt{\frac{2}{3}} \begin{bmatrix} \cos \theta & -\sin \theta \\ \sin(\theta - \pi/6) & \cos(\theta - \pi/6) \end{bmatrix} \quad (30)$$

Apply this transformation into (28)

$$\frac{d^2}{dt^2} [C_{12}^{dq} [i_{dq}]] = -\frac{R_{PF}}{L_{PF}} \frac{d}{dt} [C_{12}^{dq} [i_{dq}]] - \frac{1}{C_{PF} L_{PF}} C_{12}^{dq} [i_{dq}] - \frac{1}{L_{PF}} C_{12}^{dq} [q_{ndq}] \frac{dv_{dc}}{dt} + \frac{1}{L_{PF}} \frac{d}{dt} [C_{12}^{dq} [v_{dq}]] \quad (31)$$

With the following matrix differentiation property

$$\frac{d}{dt} [C_{12}^{dq} [i_{dq}]] = C_{12}^{dq} \frac{d}{dt} [i_{dq}] + \left( \frac{d}{dt} C_{12}^{dq} \right) [i_{dq}] \quad (32)$$

$$\frac{d^2}{dt^2} [C_{12}^{dq} [i_{dq}]] = C_{12}^{dq} \frac{d^2}{dt^2} [i_{dq}] + \left( \frac{d}{dt} C_{12}^{dq} \right) \frac{d}{dt} [i_{dq}] + \left( \frac{d}{dt} C_{12}^{dq} \right) \frac{d}{dt} [i_{dq}] + \left( \frac{d^2}{dt^2} C_{12}^{dq} \right) [i_{dq}] \quad (33)$$

Now the following relation is derived:

$$\frac{d^2}{dt^2} [i_{dq}] = - \begin{bmatrix} \frac{R_{PF}}{L_{PF}} & -2\omega \\ 2\omega & \frac{R_{PF}}{L_{PF}} \end{bmatrix} \frac{d}{dt} [i_{dq}] - \begin{bmatrix} -\omega^2 + \frac{1}{C_{PF} L_{PF}} & -\omega \frac{R_{PF}}{L_{PF}} \\ \omega \frac{R_{PF}}{L_{PF}} & -\omega^2 + \frac{1}{C_{PF} L_{PF}} \end{bmatrix} [i_{dq}] - \frac{1}{L_{PF}} [q_{ndq}] \frac{dv_{dc}}{dt} + \frac{1}{L_{PF}} \frac{d}{dt} [v_{dq}] + \frac{1}{L_{PF}} \begin{bmatrix} 0 & -\omega \\ \omega & 0 \end{bmatrix} [v_{dq}] \quad (34)$$

Now the complete model in the d-q frame is obtained from (27) and (34)

$$L_{PF} \frac{d^2 i_d}{dt^2} = -R_{PF} \frac{di_d}{dt} + 2\omega L_{PF} \frac{di_d}{dt} - \left( -\omega^2 L_{PF} + \frac{1}{C_{PF}} \right) i_d + \omega R_{PF} i_q - q_{nd} \frac{dv_{dc}}{dt} + \frac{dv_d}{dt} - \omega v_q$$

$$L_{PF} \frac{d^2 i_q}{dt^2} = -R_{PF} \frac{di_q}{dt} - 2\omega L_{PF} \frac{di_d}{dt} - \left( -\omega^2 L_{PF} + \frac{1}{C_{PF}} \right) i_q - \omega R_{PF} i_d - q_{nq} \frac{dv_{dc}}{dt} + \frac{dv_q}{dt} + \omega v_d$$

$$C_{dc} \frac{dv_{dc}}{dt} = q_{nd} i_d + q_{nq} i_q \quad (35)$$

The model is time invariant during a given switching state.

### 3.3 HARMONIC CURRENT CONTROL

$$\begin{aligned}
 L_{PF} \frac{d^2 i_d}{dt^2} + R_{PF} \frac{di_d}{dt} + (-\omega^2 L_{PF} + \frac{1}{C_{PF}}) i_d &= 2\omega L_{PF} \frac{di_q}{dt} + \omega R_{PF} i_q - q_{nd} \frac{dv_{dc}}{dt} + \frac{dv_d}{dt} - \omega v_q \\
 L_{PF} \frac{d^2 i_q}{dt^2} - R_{PF} \frac{di_q}{dt} + (-\omega^2 L_{PF} + \frac{1}{C_{PF}}) i_q &= -2\omega L_{PF} \frac{di_d}{dt} - \omega R_{PF} i_d - q_{nq} \frac{dv_{dc}}{dt} + \frac{dv_q}{dt} + \omega v_d
 \end{aligned} \tag{36}$$

$$\begin{aligned}
 u_d &= 2\omega L_{PF} \frac{di_q}{dt} + \omega R_{PF} i_q - q_{nd} \frac{dv_{dc}}{dt} + \frac{dv_d}{dt} - \omega v_q \\
 u_q &= -2\omega L_{PF} \frac{di_d}{dt} - \omega R_{PF} i_d - q_{nq} \frac{dv_{dc}}{dt} + \frac{dv_q}{dt} + \omega v_d
 \end{aligned} \tag{37}$$

Now the transfer function of the model is:

$$\frac{I_d(S)}{U_d(S)} = \frac{1}{L_{PF} S^2 + R_{PF}(S) + \frac{1}{C_{PF}} - L_{PF} \omega^2} \tag{38}$$

Transfer function of the P-I controller is given as

$$G_i(S) = \frac{U_d(S)}{I_d(S)} = \frac{U_q(s)}{I_q(s)} = k_p + \frac{k_i}{S} \tag{39}$$

The closed loop transfer function of the current loop is

$$\frac{I_q(S)}{I_q'(S)} = \frac{I_d(S)}{I_d'(S)} = \frac{k_p}{L_{PF}} \bullet \frac{S + \frac{k_i}{k_p}}{S^3 + \frac{R_{PF}}{L_{PF}} S^2 + (\frac{1}{C_{PF} L_{PF}} - \omega^2 + \frac{k_p}{L_{PF}}) S + \frac{k_i}{L_{PF}}} \tag{40}$$

The control loop of the current  $i_q$  is shown in the fig. below and the control law is

$$q_{nd} = \frac{2\omega L_{PF} \frac{di_q}{dt} + \omega R_{PF} i_q + \frac{dv_{dc}}{dt} - \omega v_q - u_d}{\frac{dv_{dc}}{dt}}$$

$$q_{nq} = \frac{2\omega L_{PF} \frac{di_d}{dt} + \omega R_{PF} i_d + \frac{dv_{dq}}{dt} - \omega v_d - u_q}{\frac{dv_{dc}}{dt}} \quad (41)$$




Fig.6. Control loop of the current.

Note that the inputs  $q_{nd}$  and  $q_{nq}$  consist of a nonlinearity cancellation part and a linear decoupling compensation part.

### 3.4 REGULATION OF DC VOLTAGE

The active filter produces a fundamental voltage which is in-phase with fundamental leading current of the passive filter. A small amount of active power is formed due to the leading current and fundamental voltage of the passive filter and it delivers to the dc capacitor. Therefore, the electrical quantity adjusted by the dc-voltage controller is consequently  $i_{q1}^*$ . To maintain  $V_{dc}$

equal to its reference value, the losses through the active filter's resistive-inductive branches will be compensated by acting on the supply current.




Fig.7 Control loop of the voltage

From (35) we can deduced to

$$C_{dc} \frac{dv_{dc}}{dt} = q_{nq} i_q \quad (42)$$

An equivalent  $u_{dc}$  is defined as  $u_{dc} = q_{nq} i_q$  (43)

Hence the reactive current of the active filter is

$$i_q = \frac{u_{dc}}{q_{nq}} - \frac{u_{dc} v_{dc}}{q_{nq} v_{dc}} \quad (44)$$

Now assume  $q_{nq} v_{dc} \approx v_{Mq}$  and  $q_{nd} v_{dc} \approx v_{Md}$

$$\text{Hence } i_q = \frac{u_{dc} v_{dc}}{v_{Mq}} \quad (45)$$

the q axes active filter voltage  $V_{Mq}$  is given by

$$v_{Mq} = -Z_{PF1} i_{q1}^*$$

Where  $Z_{PF1}$  is the impedance of the passive filter at 50 Hz and  $i_{q1}^*$  is a dc component.

The control effort of the dc-voltage loop is

$$i_{q1}^* = \frac{v_{dc}}{-Z_{PF1} i_q} u_{dc} \quad (46)$$

The three phase filter current are expressed as

$$\begin{bmatrix} i_{c1} \\ i_{c2} \\ i_{c3} \end{bmatrix} = \sqrt{\frac{2}{3}} i_q \begin{bmatrix} -\sin \theta \\ -\sin \left( \theta - \frac{2\pi}{3} \right) \\ -\sin \left( \theta - \frac{2\pi}{3} \right) \end{bmatrix} \quad (47)$$

The fundamental filter rms current  $I_c$  is given by

$$I_c = \frac{i_q}{\sqrt{3}} \quad (48)$$

The laplace form of the control effort can be derived as follows:



$$i_{q1}^*(s) = \frac{V_{dc}}{\sqrt{3}Z_{PF1}I_C} U_{dc}(s) \quad (49)$$

The outer control loop of the dc voltage is shown in Fig. To regulate dc voltage  $V_{dc}$ , the error

$\tilde{v}_{dc} = v_{dc}^* - v_{dc}$  is passing through a P-I type controller given by

$$u_{dc} = k_1 \tilde{v}_{dc} + k_2 \int \tilde{v}_{dc} dt \quad (50)$$

hence the closed loop transfer function is

$$\frac{V_{dc}(s)}{V_{dc}^*(s)} = 2\xi\omega_{nv} \frac{s + \frac{\omega_{nv}}{2\xi}}{s^2 + 2\xi\omega_{nv}s + \omega_{nv}^2} \quad (51)$$

Where  $\omega_{nv}$  is the outer loop natural angular frequency and  $\zeta$  is the damping factor.

The transfer functions of Fig. is

$$\frac{V_{dc}(s)}{V_{dc}^*(s)} = \frac{\frac{\sqrt{3}Z_{PF1}k_1I_C}{V_{dc}C_{dc}}(s) + \frac{\sqrt{3}Z_{PF1}k_2I_C}{V_{dc}C_{dc}}}{s^2 + \frac{\sqrt{3}Z_{PF1}k_1I_C}{V_{dc}C_{dc}}(s) + \frac{\sqrt{3}Z_{PF1}k_2I_C}{V_{dc}C_{dc}}} \quad (52)$$

The proportional  $k_1$  and integral  $k_2$  gains are then obtained as:

$$k_1 = 2\xi\omega_{nv} \left( \frac{V_{dc}C_{dc}}{\sqrt{3}Z_{PF1}I_C} \right)$$

$$k_2 = \omega_{nv}^2 \left( \frac{V_{dc}C_{dc}}{\sqrt{3}Z_{PF1}I_C} \right) \quad (53)$$

### **3.5 CONCLUSION**

This chapter elaborated on modeling of shunt hybrid power filter. The transformation of a-b-c to d-q reference frame is described. How the harmonic current is controlled and DC voltage is regulated, that is described in this chapter.

# Chapter 4

## **CONTROLLER DESIGN**

*Introduction*

*P-I Controller*

*Hysteresis Controller*

*Conclusion*

## 4.1 INTRODUCTION

In distributed system the harmonic current is present in a nonlinear load .By using hybrid filter we can reduced the load harmonics. But only hybrid filter is not sufficient to reduce the total harmonics of the load. Hence some controller is required to more reduce the harmonics. Different controllers are present to reduce the THD. In this chapter P-I controller and hysteresis controller are designed to compensate the load harmonics.

## 4.2 P-I CONTROLLER

In Fig. the three phase supply currents  $I_{SA}$  ,  $I_{SB}$ ,  $I_{SC}$  are measured and transformed into synchronous reference frame (d-q) axes rotating at the fundamental angular speed. Power p and q contain two components i.e. dc and ac. A dc components arising from the fundamental component of the source current, and an ac component due to its harmonic components. The ac components  $i_{dh}$ ,  $i_{qh}$  are extracted by two high pass filters and then, the harmonic component of the source current are obtained by applying the inverse transformation. To provide the inverter power losses and to maintain the DC voltage with in desired value, a dc component  $P_{Loss}$  is added to the ac component of the imaginary power. It is generated by comparing the DC capacitor voltage with its reference value and applying the error to a P-I controller. To generate the required voltage command for the active filter inverter a d-q to a-b-c transformation is applied to convert the inverter voltage command back to the three phase quantities. The reference voltage of the active power filter is achieved by multiplying ac component of the source current in gain  $k_h$  as  $v_{AF}^* = k_h i_{sh}$ .




Fig.8 Schematic diagram of SHPF with P-I controller




Fig.9 Block diagram of the Subsystem of P-I Controller

### 4.3 HYSTERESIS CONTROLLER

The load current is supplied to RMS block and PLL block. We are getting the fundamental frequency of the load current from the PLL block. This current is getting multiplied with the RMS value of the load current and the resulting current is subtracted from the load current. Hence we are getting the harmonics current. This harmonic current is fed to the hysteresis block as a reference current ( $i_{ref}$ ). The filter current is also fed to the hysteresis block as measured current ( $i_{meas}$ ). In the hysteresis block the  $i_{meas}$  is subtracted from the  $i_{ref}$  and feeding to hysteresis band, from where we are getting the switching pulses of the inverter to provide the inverter power losses and to maintain the DC voltage within its desired value.




Fig.10 Schematic diagram of SHPF with Hysteresis Controller

#### 4.4 CONCLUSION

In this chapter the hysteresis controller and P-I controller are designed and described how the load harmonics is compensated. By using two different types of controller we can got the comparative study of both the controller.

# Chapter 5

## **SIMULATION RESULTS AND DISCUSSION**

*Introduction*

*Simulation Response of Voltage Source Type Nonlinear Load*

*Simulation Response of Current Source Type Nonlinear Load*

*Conclusion*



## 5.1 INTRODUCTION

The shunt hybrid power filter which is connected to a voltage source type non-linear load is simulated by using MATLAB/SIMULINK environment. The scheme is first simulated without any filter to find out the THD of the supply current. Then it is simulated with the hybrid filter to observe the difference in THD of supply current. Simulation is also carried out with hysteresis controller and P-I controller to find out the comparative study of the THD of the supply current.

## 5.2. SIMULATION RESPONSE OF VOLTAGE SOURCE TYPE-NONLINEAR LOAD

### 5.2.1 SIMULATION RESPONSE WITHOUT FILTER




Fig.11 Wave forms of Supply Voltage (V) without filter.




Fig. 12. Wave forms of Supply Current (A) without filter




Fig.13 Wave forms of Supply Voltage (V) and Current (A) without filter.




Fig.14 Wave forms of 3-Phase Supply Current (A) Without Filter

Fig. 11 shows the supply voltage, Fig.12 shows the supply current without filter. Fig.13 shows the supply voltage and current without filter and we can see that the current is not in phase with the voltage.

## 5.2.2 SIMULATION RESPONSE WITH HYBRID FILTER




Fig.15 Wave forms of Supply Voltage (V) with hybrid filter.




Fig.16 Wave forms of Supply Current (A) with hybrid filter.




Fig.17 Wave forms of Supply Voltage and Current with hybrid filter.




Fig. 18 Wave forms of 3-P hase Supply Current (A) With hybrid Filter




Fig.19 Wave forms of filter Current (A) With hybrid Filter




Fig.20 Wave forms of Load Current (A) with hybrid filter.




Fig.21 Wave forms of DC Voltage (V) with hybrid filter

Fig.15-Fig.21 represents the simulation responses by using hybrid filter. Here we can see that in Fig. 15 the supply current harmonic is quite reduced, but in Fig.16 the current is not in phase with the voltage.

### 5.2.3 SIMULATION RESPONSE USING HYSTERESIS CONTROLLER




Fig.22 Wave forms of Supply Voltage (V) with hysteresis controller.




Fig.23 Wave forms of Supply Current (A) with hysteresis controller




Fig.24 Wave forms of Supply Voltage and Current with hysteresis controller




Fig.25 Wave forms of 3-Phase Supply Current (A) With hysteresis controller




Fig.26 Wave forms of Filter Current (A) with hysteresis controller




Fig.27 Wave forms of Load Current (A) with hysteresis controller




Fig.28 Wave forms of DC Voltage (V) with hysteresis controller

Fig.22 –Fig.28 represents the simulation responses by using hysteresis controller. We can see in Fig. 23 that the supply current harmonic is reduced as compare to hybrid filter but still in Fig. 24 the current is not in phase with the voltage.

#### 5.2.4 SIMULATION RESPONSE USING P-I CONTROLLER




Fig.29 Wave forms of Supply Voltage (V) with P-I controller.




Fig.30 Wave forms of Supply Current (A) with P-I controller




Fig.31 Wave forms of Wave forms of Supply Voltage and Current with P-I controller




Fig.32 Wave forms of 3-P hase Supply Current (A) With P-I controller




Fig.33 Wave forms of Filter Current (A) with P-I controller




Fig.34 Wave forms of Load Current (A) P-I controller




Fig.35 Wave forms of DC Voltage (V) with P-I controller

Fig.29 –Fig.35 represents the simulation responses by using P-I controller. Here we can see that in Fig.30 the supply current harmonic is reduced, but Fig. 31 the current is quite in phase with the voltage.




Fig. 36 THD (%) of the supply Current without filter




Fig.37 THD (%) of the supply Current with hybrid filter




Fig.38 THD (%) of the supply Current with hysteresis controller




Fig.39 THD (%) of the supply Current with P-I controller.

## 5.3 SIMULATION RESPONSES OF CURRENT SOURCE TYPE- NONLINEAR LOAD

### 5.3.1 SIMULATION RESPONSES WITHOUT FILTER




Fig.40 Wave forms of Supply Voltage (V) without filter.




Fig.41 Wave forms of Supply Current without filter




Fig.42 Wave forms of Supply Voltage (V) and Current (A) without filter




Fig.43 Wave forms of 3-Phase supply current without filter




Fig.44 Wave forms of Load Current (A) without filter



In current source type of nonlinear load the current harmonics is represented in Fig.41. It is very distorted. The THD is 11.27% in open loop response.

### 5.3.2 WITH HYBRID FILTER




Fig.45 Wave forms of Supply Voltage (V) without filter.




Fig.46 Wave forms of Supply Current with hybrid filter with hybrid filter.




Fig.47 Wave forms of Supply Voltage (V) and Current (A) with hybrid filter.




Fig.48 Wave forms of 3-Phase supply current with hybrid filter.




Fig.49 Wave forms of Load Current (A) with hybrid filter.




Fig.50 Wave forms of Filter Current (A) with hybrid filter.




Fig.51 Wave forms of DC Voltage with hybrid filter.

By using hybrid filter the current harmonics is reduced as compare to open loop response. The voltage and current waveforms is represented in Fig.47. The THD is reduced to 9.43%.

### 5.3.3 WITH HYSTERESIS CONTROLLER




Fig.52 Wave forms of Supply Voltage (V) with hysteresis controller.




Fig.53 Wave forms of Supply Current with hysteresis controller.




Fig.54 Wave forms of Supply Voltage (V) and Current (A) with hysteresis controller.




Fig.55 Wave forms of 3-Phase supply current with hysteresis controller.




Fig.56 Wave forms of Load Current with hysteresis controller.




Fig.5.57 Wave forms of Filter Current (A) with hysteresis controller.




Fig.5.58 Wave forms of DC Voltage with hysteresis controller.

By using hysteresis controller the current harmonics is reduced as compare to hybrid filter. The voltage and current waveforms is represented in Fig.5.4. The THD is reduced to 8.49%.

### 5.3.4 WITH P-I CONTROLLER




Fig.5.59 Wave forms of Supply Voltage (V) with P-I controller.




Fig.6.0 Wave forms of Supply Current with P-I controller.




Fig.61 Wave forms of Supply Voltage (V) and Current (A) with P-I controller.




Fig.62 Wave forms of 3-Phase supply current with P-I controller.




Fig.63 Wave forms of Load Current (A) with P-I controller.




Fig.64 Wave forms of Filter Current (A) with P-I controller.




Fig.65 Wave forms of DC Voltage (V) with P-I controller.

By using P-I controller the current harmonics is reduced as compare to hysteresis controller.

The voltage and current waveforms is represented in Fig.59-61. The THD is reduced to 4.54%

by using P-I controller.




Fig. 66 THD (%) of the supply Current without filter




Fig.67 THD (%) of the supply Current with hybrid filter




Fig.68 THD (%) of the supply Current with hysteresis controller




Fig.69 THD (%) of the supply Current with P-I controller.

The THD for different cases are represented in Fig.66 –Fig.69

# Chapter 6

## **CONCLUSION AND SCOPE OF FUTURE WORK**

*Conclusion*

*Scope of Future Work*

## 6.1 CONCLUSION

This project work presents design of shunt passive filter and shunt hybrid power filter for a distribution system. The hybrid filter reduces the harmonics as compare to open loop response. This hybrid filter is tested and verified using MATLAB program. A P-I controller and hysteresis controller is implemented for three phase shunt hybrid power filter. The P-I controller and hysteresis controller extracts the reference current from the distorted line current and hence improve the power quality parameters such as harmonic current and reactive power due to non-linear load. Here two types of non-linear load i.e. voltage source type of non-linear load and current source type of non-linear load is implementd. The harmonic current control and DC-capacitor voltage can be regulated under these two non-linear loads. We obtained it from the simulation responce. The shunt hybrid power filter is verified with the simulation results. The performance of the P-I controller and hysteresis controller is verified with the simulation results. Hence we obtained a comparative results by using this two controllers. The comparative simulation results for both type of non-linear load is presented in the table-2 and table-3



**TABLE\_2****Voltage Source Type Of Nonlinear Load**

Currents	THD (%) before Compensation	THD (%) after compensation		
		With hybrid filter	With hysteresis controller	With P-I controller
Supply current	23.24	8.51	7.05	3.19
Load current	23.24	11.11	9.77	5.93
Filter current	Nil	43.14	34.46	44.90

**TABLE-3****Current Source Type Of Nonlinear Load**

Currents	THD (%) before Compensation	THD (%) after compensation		
		With hybrid filter	With hysteresis controller	With P-I controller
Supply current	11.27	9.34	8.29	4.54
Load current	11.27	10.98	9.01	9.20
Filter current	Nil	49.41	54.63	49.82

Hence we got the simulation responses for voltage source type of nonlinear load and current source type of nonlinear load. In voltage source type nonlinear load the THD is compensated from 23.24% to 3.19 by using P-I controller which is represented in Table 2.

In current source type nonlinear load the THD is compensated from 11.27% to 4.64% which is represented in Table-3. Hence in both the case the after compensation the supply current is reduced to less than 5%, the harmonic limit imposed by the IEEE-519 & IEC-6000-3 standard.

## 6.2 SCOPE OF FUTURE WORK

Experimental investigations can be done on shunt hybrid power filter by developing a prototype model in the laboratory to verify the simulation results for both P-I and hysteresis controllers.

**TABLE-4**  
**Specification Parameters**

Phase voltage and frequency	$V_s=230\text{v(rms)}, f_s=50\text{Hz}$
Supply /line inductance	$L_{sa}=L_{sb}=L_{sc}=2\text{ mH}$
Rectifier front-end inductance	$L_{la}=L_{lb}=L_{lc}=30\text{ mH}$
For V-S Type Load resistance, load capacitance	$R_L=20\ \Omega, C_L=500\ \mu F$
For C-S Type Load resistance, load inductance	$R_L=30\ \Omega, L_L=10\text{ mH}$
Passive filter parameters	$L_{pf}=14\text{ mH}, C_{pf}=24\ \mu F$
Inverter dc- bus voltage and capacitance	$V_{dc}=50\text{v}, C_{dc}=3000\ \mu F$
Controller Parameter	$K_p=335.35, K_i=0.004$

## REFERENCES

- [1] E. F. Fuchs, M. A. S. Masoum, "Power Quality in Electrical Machines and Power Systems," Academic Press, USA, 2008.
- [2] J. C. Das, "Passive filters; potentialities and limitations," *IEEE Trans. on Industry Applications*, Vol. 40, pp. 232- 241, 2004.
- [3] B. Singh, K. Al-Haddad, and A. Chandra, "A review of active filters for power quality improvement," *IEEE Trans. Ind. Electron.*, vol. 46, no. 5, pp. 960–971, Oct. 1999.
- [4] L. Asiminoaei, E. Aeloiza, P. N. Enjeti, and F. B laabjerg, "Shunt active-power- filter topology based on parallel interleaved inverters," *IEEE Trans. Ind. Electron.* vol. 55, no. 3, pp. 1175–1189, Mar. 2008.
- [5] H. Fujita, H. Akagi, "A practical approach to harmonic compensation in power systems; series connection of passive and active filters," *IEEE Trans. on Industry Applications*, Vol. 27, pp. 1020-1025, 1991.
- [6] L. Asiminoaei, E. Aeloiza, P. N. Enjeti, and F. B laabjerg, "Shunt active-power- filter topology based on parallel interleaved inverters," *IEEE Trans. Ind. Electron.* vol. 55, no. 3, pp. 1175–1189, Mar. 2008.
- [7] B. Singh, V. Verma, A. Chandra, K. Al-Haddad, "Hybrid filters for power quality improvement," *IEEE Proc. on Generation, Transmission and Distribution*, Vol. 152, pp. 365-378, 2005.
- [8] Salem Rahmani, Abdelhamid Hamadi, Nassar Mendalek, and Kamal Al-Haddad, "A New Control Technique for Three-Phase Shunt Hybrid Power Filter," *IEEE Transactions on industrial electronics*, vol. 56, no. 8, pp. 606-805, august 2009.
- [9] B. Singh, K. Al-Haddad, and A. Chandra, "A review of filters for power quality

- improvement,” *IEEE Trans. on Industrial Electronics*, Vol. 46, pp. 960-971, 1999.
- [10] S. R. ahmani, K. Al-Haddad, and H. Y. Kanaan, “A comparative study of two PWM techniques for single-phase shunt active power filter employing direct current control strategy,” *J. IET Proc.—Elect. Power Appl.*, Vol. 1, no. 3, pp. 376–385, Sep. 2008.
- [11] N. Mendalek, K. Al-Haddad, L.-A. Dessaint, and F. Fnaiech, “Nonlinear control technique to enhance dynamic performance of a shunt active power filter,” *Proc. Inst. Elect. Eng.—Elect. Power Appl.*, vol. 150, no. 4, pp. 373–379, Jul. 2003.
- [12] L. Yacoubi, K. Al-Haddad, L. A. Dessaint, and F. Fnaiech, “A DSP-based implementation of a nonlinear model reference adaptive control for a three-phase three-level NPC boost rectifier prototype,” *IEEE Trans. Power Electron.*, vol. 20, no. 5, pp. 1084–1092, Sep. 2005.
- [13] F. Defay, A. M. Llor, and M. Fadel, “A predictive control with flying capacitor balancing of a multicell active power filter,” *IEEE Trans. Ind. Electron.*, vol. 55, no. 9, pp. 3212–3220, Sep. 2008.
- [14] R. S. Herrera, P. Salmeron, and H. Kim, “Instantaneous reactive power theory applied to active power filter compensation: Different approaches, assessment, and experimental results,” *IEEE Trans. Ind. Electron.*, vol. 55, no. 1, pp. 184–196, Jan. 2008.
- [15] R. Grino, R. Cardoner, R. Costa-Castello, and E. Fossas, “Digital repetitive control of a three-phase four-wire shunt active filter,” *IEEE Trans. Ind. Electron.*, vol. 54, no. 3, pp. 1495–1503, Jun. 2007.